VAP0R DRIVE →

PANEL THICKNESS (T)

SEALANT (NBTC)

SLIP SHEET (NBTC)

SEALANT IN SIDE JOINT

WARM

COLD

FINISH FLOOR

FIELD CUT THERMAL NOTCH (MIN. 5/8" DEEP)

FIELD APPLIED NON-CURING SEALANT IN EXTERIOR JOINT

VAPOR BARRIER (NBTC)

URETHANE SEALANT

FLOOR INSULATION (NBTC)

#12-14 X 1" HWH TYPE 3 SELF-DRILLING FASTENER @ HIGH CELLS (4 PER PANEL)

BASE TRIM

#12-14 X 1" HWH TYPE 3 SELF-DRILLING FASTENER @ HIGH CELLS (4 PER PANEL)

FIELD APPLIED CONTINUOUS BEAD OF NON-CURING SEALANT TO DAM END OF PANEL JOINT

16 GA. GALV. BASE CHANNEL

SET CHANNEL IN URETHANE SEALANT

CONCRETE FASTENER (NBTC)

NBTC = NOT BY TRUECORE

EXTERIOR BASE - COOLER

DRAWN BY:	DATE:	DRAWING NO.:	
DBN	M-D-Y		B2